

**Texas Commission on Environmental Quality  
Public Notification Form for Wastewater Discharges  
Information about the Discharge**

An unauthorized discharge or spill of wastewater has occurred from:

Wastewater Treatment Facility: \_\_\_\_\_ Collection System:   X  

Facility Name: BENBROOK WATER AUTHORITY

Person to contact for information: WILLIAM SUTTON (817) 249-1250

Location of spill(s): *1004 SHADY RIVER,1248 TIMBERLINE,1320 CONCHO,1224 TIMBERLINE,1236 TIMBERLINE,1328 TIMBERLINE,5845 BELLAIRE8103 MEADOWSIDE*

Estimated date and time of spill(s): 10/16/2018 AT 9:24AM

Estimated volume of spill(s)(number of gallons): 185,000

Type of Spill (domestic, industrial, other): DOMESTIC

Description of the area potentially affected, including down gradient and lateral distance from spill(s) site: GENERAL RESIDENTIAL. LESS THAN 500 FEET OF CREEK OR RIVER

Suspected cause of spill(s): HEAVY RAINFALL

**List of actions taken including but, not limited to:**

Notification of:

Appropriate local government officials:   X  

TCEQ Regional Office:   X  

Containment of spill: NO CONTAINMENT

Increased monitoring of water supply systems: NO HAZARDS

Initiation or completion of cleanup activities: REPAIR OF MANHOLE RINGS AND LIDS AFTER RAIN EVENT.